

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 5276-0899:0118

**CATEGORY:** Carbon Monoxide Alarms

**LISTEE:** Universal Security Instruments, 11407-A Cronhill Dr., Owings Mills, MD 21117  
Contact: Stephen Babinec (410) 363-3000 Fax (410) 363-2218  
Email: steveb@universalsecurity.com

**DESIGN:** Model MCN400 and MCND401 direct plug-in (120 VAC with 9 VDC battery back-up), single station, carbon monoxide alarms. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120 VAC with 9 VDC battery back-up

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as Carbon Monoxide alarms for residential applications. Refer to listee's Installation Instructions Manual for details.

**NOTE:** Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

01-30-12 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **January 31, 2012**

Listing Expires **June 30, 2012**

Authorized By: **JASON DEWITT**, Deputy State Fire Marshal  
Fire Engineering Division